



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/748/2025

Date – 31/01/2025

To
The Principal,
Pune International School,
Charholi.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Pune International School, Charholi. on Date: 27/01/2025 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /741/2025 dated 29/01/2025 & ws /lab /738/2025 dated 28/01/2025 the water Sample is safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory.

Chief Chemist
Pimpri Chinchwad Municipal Corporation
Pimpri -18

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION

No-WS/LAB/738/2025.

Date-28/01/2025.

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

NAME - Pune International School.

DATE OF EXAMINATION -27/01/2025.

ADDRESS - Charholi.

SOURCE -

NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Collforms	E.Coll	
1	Water Sample	0.1ppm	0/100ml	-	Potable.
2					 CHIEF CHEMIST Water Treatment Plant Pimpri Chinchwad Municipal Corp. Nigdi, Pune 44
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Pune International School.

No-WS/LAB/741 /2025.

ADDRESS - Charholi.

Date - 29 / 01 /2025.

Date of Receipt - 27 / 01 /2025.

SOURCE -

Date of Examination - 28 / 01 /2025.

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	2.16 NTU.		
2	pH	6.5 to 8.5	7.98		
3	Total Hardness (as CaCO3)	200 mg/lit	108 mg/lit		
4	Chloride	250 mg/lit	32 mg/lit		
5	Calcium	75 mg/lit	27.25 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC