



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune – 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/2237/2026

Date – 18/02/2026

To

The Principal,
Pune International School,
Charholi.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Pune International School, Charholi on Date: 05/02/2026 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /2158/2026 dated 07/02/2026 & ws /lab /2162/2026 dated 07/02/2026 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER



No-WS/LAB/2162/2026.

Date - 07 / 02 / 2026.

NAME - पुणे इंटरनेशनल स्कूल

DATE OF EXAMINATION - 05 / 02 / 2026.

ADDRESS - चहोली.

SOURCE -

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	Nil	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - पुणे इंटरनेशनल स्कूल

No-WS/LAB/2158/2026.

Date - 07 / 02 /2026.

ADDRESS - चखोली.

Date of Receipt - 06 / 02 /2026.

SOURCE -

Date of Examination - 06 / 02 /2026.

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.40 NTU.		
2	pH	6.5 to 8.5	7.60.		
3	Total Hardness (as CaCO3)	200 mg/lit	124 mg/lit		
4	Chloride	250 mg/lit	32 mg/lit		
5	Calcium	75 mg/lit	35.27 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST

WATER TREATMENT PLANT, NIGDI, PCMC

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

PIMPRI-411018

Health Department,

**Email - healthho@pcmcindia.gov.in
www.pcmcindia.gov.in**

Website -

**Phone No. 020 - 67333333
Ext.No.1336**

**No. Zone/06/kavi/ 326
12/02/2026**

Date -

"Safe drinking water and sanitary condition certificate"

It is certified that an inspection team headed by "Health Department" of Pimpri Chinchwad Municipal Corporation, Pimpri, Pune - 411018 From Assistant Commissioner, Health Department, Pimpri Chinchwad Municipal Corporation, Pimpri - 411018. Inspected Pune International School Charholi Bk, Tal Haveli PCMC Pune 412105 On 21/01/26 checked the water test reports, submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building and the campus as per norms prescribed by the State governments norms.

The above is valid for a period of one year from the date of issue.

(Deputy Commissioner)

HEALTH DEPARTMENT

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

PIMPRI - 411 018.

To,

Principal

Pune International School



Attachment :

Signature 1 Name:

Signature Not Verified
Name : P D THENGAL
Designation: Deputy Commissioner
Location
Date : 12-02-2026 12:06

----- This Note ends here. / ही नोंद इथे संपते. -----